



TÜRKAK
TÜRK AKREDİTASYON KURUMU

TURKISH ACCREDITATION AGENCY
tarafından akredite edilmiştir



EFFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş.

Dilovası OSB, 5. Kısım, Fırat Caddesi No:18, Dilovası, KOCAELİ/TÜRKİYE

DENEY RAPORU

TEST REPORT

AB-0556-T

20.05.2019

RFTR19112

Müşterinin adı/adresi : ISONEM BOYA VE YALITIM TEKNOLOJİLERİ İNŞ. SAN. TİC. A.Ş.
Customer name/address İTOSB OSB, 10001 Sk. No:20, Tekeli, Menderes, İZMİR, TURKEY

İstek numarası : EEA-18-000393
Order No.

Numunenin adı ve tarifi : Fire Resistance Intumescent Paint For Structural Steels "ISONEM Anti-Fire Paint Plus" – (Short columns)
Name and identity of test sample

Numunenin kabul tarihi : 13.11.2018
The date of receipt of sample

Açıklamalar :
Remarks

Deneyin yapıldığı tarih : 16.04.2019
Date of test

Raporun sayfa sayısı : 13 (25 pages including appendixes)
Number of pages of the Report

Türk Akreditasyon Kurumu(TÜRKAK) deney raporlarının tanınması konusunda Avrupa Akreditasyon Birliği(EA) ve Uluslararası Laboratuvar Akreditasyon Birliği(ILAC) ile karşılıklı tanınma antlaşmasını imzalamıştır.

The Turkish Accreditation Agency(TURKAK) is signatory to the multilateral agreements of the European co-operation for the Accreditation(EA) and of the International Laboratory Accreditation(ILAC) for the Mutual recognition of test reports

Deney ve /veya ölçüm sonuçları, genişletilmiş ölçüm belirsizlikleri (olması halinde) ve deney metotları bu sertifikanın tamamlayıcı kısmı olan takip eden sayfalarda verilmiştir.

The test and/or measurement results, the uncertainties (if applicable) with confidence probability and test methods are given on the following pages which are part of this report

Mühür
Seal

Tarih
Date

Deney Sorumlusu
Person in charge of test

Laboratuvar Müdürü
Head of Testing Laboratory



20.05.2019

Mustafa Emre ÖZBEY

Ali BAYRAKTAR

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid

1. SCOPE

Fire resistance test, in conformity with the general requirements of standards EN 1363-1:2012, with substitute or additional methods of standard EN 1363-2:1999 and with the particular requirements of standard EN 13381-8:2013 "Test methods for determining the contribution to the fire resistance of structural members - Part 8: Applied reactive protection to steel members".

2. TEST LABORATORY

Name : Efectis Era Avrasya Test ve Belgelendirme A.Ş.

Address : Dilovası OSB, 5. Kısım, Fırat Caddesi No:18, Dilovası, KOCAELİ/TURKEY

3. DESCRIPTION OF THE TEST SPECIMEN**3.1. General**

Product identification: Fire Resistance Intumescent Paint For Structural Steels "**ISONEM Anti-Fire Paint Plus**" – (Short columns)

Manufacturer of paint : ISONEM BOYA VE YALITIM TEKNOLOJİLERİ İNŞ. SAN. TİC. A.Ş.
İTOSB OSB, 10001 Sk. No:20, Tekeli, Menderes, İZMİR, TÜRKİYE

Sponsor of test : ISONEM BOYA VE YALITIM TEKNOLOJİLERİ İNŞ. SAN. TİC. A.Ş.
İTOSB OSB, 10001 Sk. No:20, Tekeli, Menderes, İZMİR, TÜRKİYE



Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid

3.2. Preparation of Test Specimens

3.2.1. Steel Profiles

The steel profiles were supplied by the test laboratory include HEA 140 and IPE 80 profiles. The specimens were described below in the Table 1.

Table 1: Test specimens

Test specimen	Steel Symbol	Type of steel section	Length (mm)	Protection thickness (μm)
Unloaded Short Column	SC-1	HEA 140	1000	1500
Unloaded Short Column	SC-2	HEA 140	1000	7500
Unloaded Short Column	SC-3	HEA 140	1000	5100
Unloaded Short Column	SC-4	IPE 80	1000	5100
Unloaded Short Column	SC-5	IPE 80	1000	7500
Unloaded Short Column	SC-6	IPE 80	1000	3300
Unloaded Short Column	SC-7	HEA 140	1000	3300

Table 2: Details of profiles

No.	Symbol	Section type	Heating	Profile	Measured values						
					h [mm]	b [mm]	t _r [mm]	t _w [mm]	P [mm]	A [mm ²]	Section factor [m ⁻¹]
1	SC-1	open	4 sides	HEA 140	133	142	8,6	6,1	819	3139	261
2	SC-2	open	4 sides	HEA 140	134	140	8,6	6,1	816	3109	263
3	SC-3	open	4 sides	HEA 140	133	141	8,6	6,1	819	3133	261
4	SC-4	open	4 sides	IPE 80	80	45	4,6	4,0	334	703	475
5	SC-5	open	4 sides	IPE 80	80	45	5	4,0	333	695	479
6	SC-6	open	4 sides	IPE 80	80	45	4,6	4,0	333	697	478
7	SC-7	open	4 sides	HEA 140	133	141	8,6	6,1	817	3123	261



Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid




Figure 1: Profile details

3.2.2. The fire protection system

The fire protection system consists of Fire Resistance Intumescent Paint For Structural Steels "ISONEM Anti-Fire Paint Plus"

Table 3: Measured points of the HEA 140 (1500 µm)

Results	MEAN	MIN	MAX	MEAN -20%	MEAN +20%	MEAN -30%	MEAN +30%	MEAN -45%	MEAN +45%	% of readings within limit			Result
	1584	1340	1745	1267	1901	1109	2060	871	2297	±20%	±30%	±45%	
	Deviation = 15,4%								Requirements	68%	95%	100%	PASS

											% of readings within limit			
Measurement no.:		1	2	3	4	5	6	7	8	9	10	±20%	±30%	±45%
Measuring points	1. Position 1 temperature measurement station	1567	1580	1574	1658	1541	1420	1638	1740	1745	1465	100%	100%	100%
	2. Position 2 temperature measurement station	1340	1538	1540	1630	1640	1504	1630	1632	1675	1630	100%	100%	100%
	Requirements											68%	95%	100%

All measurements in [µm]

All measurements in [µm]



Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid

Table 4: Measured points of the HEA 140 (7500 µm)

Results	MEAN	MIN	MAX	MEAN -20%	MEAN +20%	MEAN -30%	MEAN +30%	MEAN -45%	MEAN +45%	% of readings within limit			Result
	8199	7442	8614	6559	9839	5739	10659	4510	11889	±20%	±30%	±45%	
	Deviation = 9,2 %			Requirements						68%	95%	100%	PASS

											% of readings within limit			
Measurement no.:		1	2	3	4	5	6	7	8	9	10	±20%	±30%	±45%
Measuring points	1. Position 1 temperature measurement station	8614	8439	8585	8412	8205	7578	7649	8343	8550	8128	100%	100%	100%
	2. Position 2 temperature measurement station	8349	8256	7565	8238	7442	8556	7944	8311	8225	8593	100%	100%	100%
										Requirements	68%	95%	100%	

All measurements in [µm]

Table 5: Measured points of the HEA 140 (5100 µm)

Results	MEAN	MIN	MAX	MEAN -20%	MEAN +20%	MEAN -30%	MEAN +30%	MEAN -45%	MEAN +45%	% of readings within limit			Result
	5480	5200	5885	4384	6576	3836	7124	3014	7946	±20%	±30%	±45%	
	Deviation = 7,4 %			Requirements						68%	95%	100%	PASS

											% of readings within limit			
Measurement no.:		1	2	3	4	5	6	7	8	9	10	±20%	±30%	±45%
Measuring points	1. Position 1 temperature measurement station	5522	5379	5672	5402	5379	5429	5320	5220	5200	5250	100%	100%	100%
	2. Position 2 temperature measurement station	5365	5447	5796	5885	5347	5693	5700	5630	5409	5553	100%	100%	100%
											Requirements	68%	95%	100%

All measurements in [µm]



Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid

Table 6: Measured points of the IPE 80 (5100 µm)

Results	MEAN	MIN	MAX	MEAN -20%	MEAN +20%	MEAN -30%	MEAN +30%	MEAN -45%	MEAN +45%	% of readings within limit			Result
	5330	5109	5580	4264	6396	3731	6929	2932	7729	±20%	±30%	±45%	
	Deviation = 4,7%								Requirements	68%	95%	100%	PASS

												% of readings within limit		
Measurement no.:		1	2	3	4	5	6	7	8	9	10	±20%	±30%	±45%
Measuring points	1. Position 1 temperature measurement station	5218	5319	5322	5469	5337	5445	5193	5468	5245	5421	100%	100%	100%
	2. Position 2 temperature measurement station	5326	5109	5337	5109	5261	5567	5266	5419	5580	5193	100%	100%	100%
										Requirements		68%	95%	100%

All measurements in [µm]

Table 7: Measured points of the IPE 80 (7500 µm)

Results	MEAN	MIN	MAX	MEAN -20%	MEAN +20%	MEAN -30%	MEAN +30%	MEAN -45%	MEAN +45%	% of readings within limit			Result
	7877	7411	8148	6302	9453	5514	10240	4332	11422	±20%	±30%	±45%	
	Deviation = 5,9%								Requirements	68%	95%	100%	PASS

											% of readings within limit			
Measurement no.:		1	2	3	4	5	6	7	8	9	10	±20%	±30%	±45%
Measuring points	1. Position 1 temperature measurement station	8093	7694	7955	7994	7858	7415	7976	8057	7583	8055	100%	100%	100%
	2. Position 2 temperature measurement station	7411	7818	7844	7955	8065	8126	7590	7969	8148	7937	100%	100%	100%
											Requirements	68%	95%	100%

All measurements in [µm]



Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid

Table 8: Measured points of the IPE 80 (3300 µm)

Results	MEAN	MIN	MAX	MEAN -20%	MEAN +20%	MEAN -30%	MEAN +30%	MEAN -45%	MEAN +45%	% of readings within limit			Result
										±20%	±30%	±45%	
	3480	3319	3679	2784	4176	2436	4524	1914	5046	100%	100%	100%	PASS
	Deviation = 5,7%								Requirements	68%	95%	100%	

		Measurement no.:										% of readings within limit		
		1	2	3	4	5	6	7	8	9	10	±20%	±30%	±45%
Measuring points	1. Position 1 temperature measurement station	3378	3669	3495	3512	3472	3415	3569	3562	3520	3349	100%	100%	100%
	2. Position 2 temperature measurement station	3350	3377	3491	3319	3495	3462	3509	3679	3492	3482	100%	100%	100%
		Requirements										68%	95%	100%

All measurements in [µm]

Table 9: Measured points of the HEA 140 (3300 µm)

Results	MEAN	MIN	MAX	MEAN -20%	MEAN +20%	MEAN -30%	MEAN +30%	MEAN -45%	MEAN +45%	% of readings within limit			Result
										±20%	±30%	±45%	
	3503	3069	3792	2802	4204	2452	4554	1927	5079	100%	100%	100%	PASS
	Deviation = 12,4%								Requirements	68%	95%	100%	

		Measurement no.:										% of readings within limit		
		1	2	3	4	5	6	7	8	9	10	±20%	±30%	±45%
Measuring points	1. Position 1 temperature measurement station	3666	3291	3440	3423	3370	3685	3394	3708	3550	3575	100%	100%	100%
	2. Position 2 temperature measurement station	3471	3311	3405	3069	3537	3567	3792	3743	3481	3582	100%	100%	100%
		Requirements										68%	95%	100%

All measurements in [µm]



Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid

- Type: Steel Fire Protection Paint is a water base acrylic coating fire retardant. This coat is specially designed as passive fire protection for steel constructions. Coat can be applied for structural steel exposed and internal environments.
- Thickness: Thickness measurements were reached by applying 400 µm per a day. 24 hours drying interval is waited between application of each layer.
- Paint : Water based fire retardant intumescent paint
 - Nominal density : 1150±0.05 kg/m³
 - Measured density: 1288.32 kg/m³
 - Nominal thickness: 1.5-7.5 µm

3.2.2. Application

"ISONEM Anti-Fire Paint Plus" paint was applied on the surface with the spray machine that work with the air. The paint was applied by brush for strips and small areas. The epoxy based prime paint that has 50 µm thicknesses was applied on the columns before the test to protect from corrosion

*Brand, type, quantity and dimension information of the components, when it is not possible to be verified by the laboratory, are given according to the sponsor's declaration.

4. PRE-TEST PROCESSES

4.1. Verification of specimen

Efectis Era Avrasya A.S. verified the used materials and parts against the supplied data and drawings during installation of the test specimen and not involved in the selection of test specimen.

The test specimen was assembled by sub-contractor of the test sponsor with the witness of manufacturer.

4.2. Thickness measurement

Thickness measurement was checked and documented on the test specimens by the laboratory.

4.3 Conditioning

The construction was stored in the laboratory of Efectis Era Avrasya A.S. under the following conditions:

- Ambient temperature : 13,8 ± 1,5 °C.
- Relative humidity : 55,0 ± 4,0 %.
- Conditioning time : 31 days



Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid

5. TEST PROCESS

5.1. Method

The fire test was conducted according to the EN 13381-8:2013.

The heating of the furnace followed the standard fire curve, as specified in the EN 1363-1:2012

The target overpressure in the furnace was 20 Pa 100 mm below the furnace ceiling

5.2. Measurements

Following test data were measured during the test:

- During the heating, the following data was measured and registered:
- Gas temperatures inside the furnace with ten plate thermocouples (TC1 to TC3 and TC8 to TC9), evenly distributed over the directly heated surface (see figure A1).
- The pressure in the furnace, measured at a height of 2,9 meter above the furnace floor level (see figure A3).
- Ambient temperature in the laboratory (see figure A4).
- The steel temperatures (TC 1 to TC 9) (see figure B2-B8).
- There is no need to use roving thermocouple.
- The positions of the thermocouples measurement are given in figure (B1).

6. OBSERVATIONS

Table 9: Observations during the test.

0	Heating started.
18	F- Cracked occurred at the surface of the columns.
78	SC-6 temperature increased at Thermocouple Avr., $\Delta T \geq 750$ °C.
86	SC-4 temperature increased at Thermocouple Avr., $\Delta T \geq 750$ °C.
103	SC-1 temperature increased at Thermocouple Avr., $\Delta T \geq 750$ °C.
114	SC-7 temperature increased at Thermocouple Avr., $\Delta T \geq 750$ °C.
122	SC-3 temperature increased at Thermocouple Avr., $\Delta T \geq 750$ °C.
149	SC-5 temperature increased at Thermocouple Avr., $\Delta T \geq 750$ °C.
187	SC-2 temperature increased at Thermocouple Avr., $\Delta T \geq 750$ °C.
189	Test was terminated due to failure of design temperature.



Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid

7. TEST RESULTS

7.1 Results

The results are given in table 10 and appendixes B and C.

During the heating the temperature in the laboratory complied with the standard EN 1363-1:2012.

7.2 Uncertainty of measurements

Due to the nature of fire resistance testing, in which several non-linear effects are present in both the test configuration and the test specimen, which influence each other, it is at this moment not yet possible to give a stated degree of uncertainty of measurement.

8. SUMMARY

The most important results of the examination are given in table 10.

Table 10: Summary of test results of the loaded beam

Insulation:, [I] – Average temperature	(SIC-6) 78. minute (750°C). (SIC-4) 86. minute (750°C). (SIC-1) 103. minute (750°C). (SIC-7) 114. minute (750°C). (SIC-3) 122. minute (750°C). (SIC-5) 149. minute (750°C). (SIC-2) 187. minute (750°C).
The heating was terminated at 189 th minute after failure	

This report provides the constructional details, the test conditions, the results obtained and the interpolated data obtained when the specified fire protection system described herein was tested following the procedures of EN 13381-8. Any deviation with respect to thickness and density of fire protection material and constructional details, loads, stresses, edge or end conditions other than those allowed under the field of application could invalidate the test result.




Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid

9. DRAWINGS



Column elevation


Figure 2: Section view of the column

Efectis

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid



I or H column plan

Figure 2: Cross section details of the column



Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid

APPENDIXES:

Appendix A: Furnace and laboratory conditions

Appendix B: Test results

Appendix C: Photos



Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid




Figure A1: Furnace Temperatures




Figure A2: Deviation of furnace temperature

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid




Figure A3: Pressure in the furnace

- The sudden peaks caused by the parts of the specimen fallen inside to the furnace.





Figure A4: Ambient temperature at laboratory


Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid



Position 1



Position 2




Figure B1: Locations of thermocouples of columns

Efectis

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid




Figure B2: Surface temperatures of SC1 (TC1 –TC9 and Web Avr. Temp)

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid




Figure B3: Surface temperatures of SC2 (TC1 –TC9 and Web Avr. Temp)

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid




Figure B4: Surface temperatures of SC3 (TC1 –TC9 and Web Avr. Temp)

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid




Figure B5: Surface temperatures of SC4 (TC1 –TC9 and Web Avr. Temp)

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid




Figure B6: Surface temperatures of SC5 (TC1 –TC9 and Web Avr. Temp)

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid




Figure B7: Surface temperatures of SC6 (TC1 –TC9 and Web Avr. Temp)

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid




Figure B8: Surface temperatures of SC7 (TC1 –TC9 and Web Avr. Temp)

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürsüz raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid



Photo C1: The aspect of columns before the test

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid



Photo C2: The aspect of columns after the test

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid